# ATTACHMENT

## Your Seattle Fire Department

Claude Harris, Chief Charles Royer, Mayor

November 5, 1987



RECEIVED

110A 6 - 1881

Environmental Affairs Division

Shirli Axelrod City Light Environmental Affairs Room 922 1015 3rd Avenue Seattle, WA 98104

Dear Shirli Axelrod:

This is in response to your letter of October 15,1987 regarding underground fuel tanks at Georgetown Steam Plant.

The removal of the four steel tanks used for fuel oil and diesel fuel is required per SFC 79.113.

The 465 gallon steel tank used for water storage doesn't constitute the same liability under the Fire Code. In the interest of safety the Seattle Fire Department recommends it be removed or filled with slurried cement because of possible collapse in the future.

Your proposal to demolish the above-ground concrete tank is approved with proper cleaning of residue and cover the remaining portion with clean fill dirt.

In regards to permit requirements for abaondoning underground tanks:

- a. Done under Permit from the City of Seattle Fire Department.
- b. Per Seattle Fire Code Section 79.113.
- c. All tanks to be certified gas free by Marine Chemist prior to removal.
- d. See attached information.

If you have any further questions, contact Inspector Don Brenneman at 625-4077 regarding this matter.

Very truly yours,

CLAUDE HARRIS, CHIEF Seattle Fire Department

B. L. Hansen, Fire Marshal

BLH:DB:sr

Attachment

An equal employment opportunity - affirmative action employer.

City of Seattle—Fire Department, 301 Second Avenue South, Seattle, Washington 98104, (206) 625-4081



## NOT A VALID PERMIT

# INSPECTOR WILL INSPECT JOB SITE AND ISSUE PERMIT

- CONDITIONS: 1. TANKS MAY BE REMOVED ONLY AFTER FIRE DEPARTMENT INSPECTION.
  - Two (2) 20 BC portable fire extinguishers are to be on site within 50' of the operation.
  - 3. Rope or ribbon barricades must be provided circling 10' from the operation or be enclosed in a fenced yard.
  - "No Smoking" signs must be posted in readily visible locations.
  - No hot works allowed unless the tanks are certified gas free. A separate Fire Department permit (Code 491) is required for cutting and welding operations.

### PROCEDURES:

- 356-1450 Call 625-4077, 24 hours prior to removal to arrange for an appointment.
- 2. Additional fees will be charged if inspectors are required to work other than normal business hours. (Normal Business Hours are 7:30 A.M. to 4:30 P.M.)
- Tank to be completely empty of all flammable or combustible liquids prior to removal.
- To ensure that the tank atmosphere has been inerted, one (1) pound of dry ice (Carbon dioxide) per 50 gallon capacity of the tank must be inserted in the tank. (A 1000 gallon tank would require 20 pounds of dry ice.) This should be done prior to the use of heavy equipment for excavating.
  - Wait a minimum of 60 minutes for dry ice to vaporize. Vapors should begin to show at the fill pipe at this time.
  - A Fire Marshal's Office Inspector will test with a Carbon dioxide tester. When a reading of 60% CO2 is achieved, tank removal may begin.
  - c.  ${\rm CO_2}$  fire extinguishers or compressed gas are not to be used for inerting purposes. This produces static electricity which may result in an explosion.

A COPY OF PERMIT, CONDITIONS AND A SET OF THE APPROVED FLANS MUST BE ON THE SITE AT ALL TIMES DURING CONSTRUCTION.

F-200 rev. 4/87

()

contractor

lessee

other

KCSlip4 59904

DEC 21 1987

Grading File No.: 2946 26 Applicant's Name: Sentice

In acceptance of this Grading permit the applicant does hereby acknowledge that failure to compl with all the conditions set forth herein shall necessitate an immediate work stoppage until suctime as compliance with the stipulated conditions is attained. Additionally, the granting of this nermit should not be construed as artisfulor the requirements of the construed as artisfulor the requirements of the construed as artisfulor the requirements. this permit should not be construed as satisfying the requirements of any other Federal, State a local permits or authorizations. The operation to be undertaken through this Grading permit sha be conducted in accordance with the following conditions:

- A. STANDARD CONDITIONS OF APPROVAL.
  - 1. No external signs shall be permitted except those authorized by the King County foning Code or as required by this permit.
  - 2. Hours of operation shall be limited to 7.00 a.m. to 7.00 p.m., Monday through

Acres 1

- J. As a measure to minimize problems of dust, mud and traffic circulation, on-site access roads shall be located and maintained to the satisfaction of the King County Department of Public Works.
- The permittee shall maintain a liability policy in the amount of \$100,000.00 per individ: s. The permittee shall maintain a liability policy in the amount of stoutous per individual \$100,000.00 per occurrence and \$50,000.00 property damage naming King County as an additional insured. The additional insured clause must read: "It is hereby understood and agreed that King County, its appointed and elected officials and employees, while acting within the scope of their duties as aut is named as an additional insured." No other wording will be accepted.
- 3. The permittee shall abide by the regulations of the Puget Sound Air Pollution Control Ag
- The permittee shall abide by the provisions of King County Ordinance #3139 relating to n
- Temporary settling ponds must be constructed in accordance with King County Ordinance #2 Chapter 20.90 K.C.C.
- If at any time truck traffic generated by this grading operation interferes with normal traffic flows within the immediate aren, flag men shall be required.
- 9. The permittee shall notify the Building & Land Development Division (8 hours prior to th commencement of grading activities (206) ==44=7900 Grading Section.
- 10. Any scructures on filled areas shall comply with the conditions of the Uniform Building Code relating to the placement of building foundations.
- CONDITIONS PURSUANT TO K.C.C. 16.82.100 and 16.82.110:
  - 16.82.100 Operating conditions and standards of performance. Cuts and fills shall conform t the provisions of this section unless otherwise approved by the director.
  - (1) SLOPE. Ho slope of cut and fill surfaces shall be stoeper than is safe for the intended use and shall not exceed two horizontal to one vertical, unless otherwise approved by the
  - All disturbed areas including faces of cuts and fill slopes shall be (2) EROSION CONTROL.. prepared and maintained to control erosion. This control may consist of effective planting. The protection for these areas shall be installed as soon as practical and prior to bond release. Where areas are not subject to erosion, as determined by the director, such protection may be omitted.
  - (3) PREPARATION OF GROUND. The ground surface shall be prepared to receive fill by removing unsuitable material such as concrete slabs, tree stumps, brush and car bodies.
  - (4) FILL MATERIAL. Except in an approved sanitary landfill, only earth materials which have no rock or similar irreducible material with a maximum dimension greater than eighteen inche shall be used.
  - (5) DRAINAGE. Provisions shall be made to:
  - (a) Provent any surface water or seepage from damaging the cut face of any excavations (the sloping face of a fill;
    (b) Carry any surface waters that are or might be concuntrated as a result of a fill or
  - excavation to a natural watercourse, or by other means approved by the Department of Public
    - (c) Prevent any sediment from leaving the site.
  - (6) BENCH/TERRACE. Benches, if required, at least ten feet in width shall be back-sloped a shall be established at not more than twenty-five feet vertical intervals to control surfac drainage and debris. Scales or ditches on benches shall have a maximum gradient of five percent.
  - (7) ACCESS ROADS MAINTENANCE. Access roads to grading sites shall be maintained and loca to the satisfaction of the King County Department of Public Works to minimize problems of d mud and traffic circulation.
  - (8) ACCESS ROADS GATE. Access roads to grading sites shall be controlled by a gate when required by the director.
  - 191 WARNING SIGNS. Signs warning of hazardous conditions, if such exist, shall be affixed locations as required by the director.
  - (10) FINCING. Fencing, where required by the director, to protect life, limb and property shall be installed with lockable gates which must be closed and locked when not working the site. The fence must be no less than five feet in height and the fence material shall have horizontal opening larger than two inches.
  - (11) SETBACKS. The tops and the toes of cut and fill slopes shall be set back from property boundaries as far as necessary for safety of the adjacent properties and to prevent damage resulting from water runoff or erosion of the slopes. (over)

F-200-(c)

rev. 6/84

1 of 2

Light to the s المشابها المالية

	netessary for adequacy of fo lation support provent persons desired of water runtit or excession of the slopes.
•	or erosion of the slopes. Slopes and setbacks shall be decormined by the director
	(12) EXCAVATIONS TO MATER-PRODUCING DEPTH. All excavations must either be made to a water-producing depth or grade to permit natural drainage. The excavations made to a water-product depth shall be reclaimed in the following manner:  (a) The depth of the excavations must not be less than two feet measured below the low-
	vater mark.  (b) All banks shall be sloped to the vater line no steeper than three feet horizontal to
	one foot vertical.  (c) All bonks shall be sloped from the low water line into the pond or lake with a minimal slope of three feet horizontal to one foot vertical to a distance of at least twenty-five feed (d) In no event shall the term water-producing depth as herein used be construed to allow stagnant or standing water to collect or remain in the excavation.
	the establishment of a lake of sufficient area and depth of vater to be useful for recreational purposes.
	(13) HOURS OF OPERATION. Hours of operation, unless otherwise authorized by the director.shr be between soven a.m. and seven p.m.
	(14) CONTINUOUS SPECIAL INSPECTION - Storm sever and underground utilities installation requires continuous inspection by a licensed engineer or representative of an approved testing laboratory, with periodic progress reports submitted to B.A.L.D.'s grading section (Neil Gaunce 344-7900). RANDY SANDIN 294-6410
	(15) CALL BEFORE YOU DIG - Effective June 6, 1984, you must call 1-800-424-5555 not les than 48 hours before beginning excavation where any underground utilities may be locate Failure to do so could mean bearing substantial repair costs (up to three times the cos of repairs to the service).
	(16) This permit does not approve road design and/or location. Additional permits and approvals will be required.
	(17) CALL FOR INSPECTION - (344-7990) after installation of erosion and sediment contro and prior to construction. 296-6610
16.82.110 LAND RESTORATION.	
	(1) Upon the exhaustion of minerals or materials or upon the permanent abandonment of the quarrying or mining operation, all nonconforming buildings, structures, apparatus or appurtenances accessory to the quarrying and mining operation shall be removed or otherwise dismantled to the satisfaction of the director. This requirement shall not require land restoration on projects completed prior to January 1, 1971, except those covered under previously existing roning requirements.
	(2) Final grades shall be such so as to encourage the uses permitted within the underlying a classification.
	(3) Grading or backfilling shall be made with nonnoxious, nonflammable, noncombustible and n purrescible solids.
	(4) Such graded or backfilled areas, except for roads, shall be sodded or surfaced with soil a quality at least equal to the topsoil of the land areas immediately surrounding, and to a depth of at least four inches or a depth of that of the topsoil of land areas immediately su rounding if less than four inches.
	(5) Such topsoil as required by subdivision (4) shall be planted with trees, shrubs, lagumes grasses, and said flora shall be so selected as to be indigenous to the surrounding area.
	(6) Graded or backfilled areas shall be reclaimed in a manner which will not allow water to collect and permit stagnant water to remain. Suitable drainage systems approved by the Department of Public Works shall be constructed or installed if natural drainage is not poss (7) Waste or soil piles shall be leveled and the area treated as to sodding or surfacing and
	(7) Waste or soil piles shall be leveled and the area treated as to sodding or surfacing and planting as required in subdivisions (4) and (5) of this section.
C	ADDITIONAL CONDITIONS listed hereafter and/or on supplemental sheet attached.  (1) Sec Affached
	(2)
	(3)
	(5)
	Grading Pérmit and conditions of approval accep
	hy D 2/2/28
- 1	TECHNITAL COUNTYTEE:
13.3	The first sand Development Division TAUFIC DIVISION, Department of Figure Active
::	7. Suilling & Land Davelopment Division ASDANLICS Division, Department Of Figure Horks.

Planning Division, Dept. Flan. & Com. Dev.

# Additional Conditions of Approval for

## Grading Permit #2946-26

- 1. Nothing in this approval shall conflict with requirements of other permits or approvals. In the event of a conflict, all site work shall cease until the conflict is resolved.
- 2. All unsuitable or surplus excavated or cleared material to be removed from the site shall be disposed of in an approved, legal fill site. It will be permittees responsibility to locate acceptable disposal sites and assure that all surplus material is disposed of in same. Prior to removing any material from the site, contact the Grading Section at 344-7935.
- 3. Please be advised that a demolition permit will be required for removal of existing on-site structures.
- 4. Prior to the start of any work, call Martha Burnham of the Grading Section at 344-7935 to arrange a pre-construction meeting. Please be advised that this permit shall not be effective until the Notice to Proceed has been issued.

Grading permit and conditions of approval accepted and received by:

2 /3 /5°2 Name Date

GRADING TECHNICAL COMMMITTEE: